

## ***Additional reaction to fire classification report No. 13854E***

### **Owner of the additional classification report**

Sentec International BV  
Pascallaan 36  
8218 NJ Lelystad  
The Netherlands

### **Introduction**

This additional classification report defines the classification assigned to the product '**DESARDI® CLASSIC 290G**' in accordance with the procedures given in the standard EN 13501-1:2007+A1:2009: Fire classification of construction products and building elements - Part 1: classification using data from reaction to fire tests.

**This additional classification report consists of 6 pages**

This report is additional to that issued as No. 13854A, dated 10/03/2014. This report is drafted in accordance with the regulations of EGOLF Agreement EGA 08rev2:2013 "Application note: clause 5.10 / 4-2 – Amendment of reports: client changing product/company names (ii) for commercial reasons – Issue of additional reports". The original report remains valid and is not replaced by this report. The product has not been retested and this report does not involve technical changes or technical reviews of the original report. The original and the new name of the product/sponsor and of the company commercially responsible for the product, as well as the declarations concerning this additional report, are documented by the laboratory and maintained in the laboratory records.

## 1. DETAILS OF CLASSIFIED PRODUCT

### a) Nature and end use application

The product **DESARDI® CLASSIC 290G** is defined as a 'decorative wall covering'.  
Its classification is valid for the following end use application(s):  
Used for attaching onto walls or ceilings, by means of an adhesive.

### b) Description

*This description is based on information given by the sponsor.*

Nominal values	
<b>PRODUCT: DESARDI® CLASSIC 290G</b>	
Type of product	The product DESARDI® CLASSIC 290G consists of a vinyl based wall covering with a paper backing.
Total surface mass (g/m <sup>2</sup> )	300
Layer 1: Vinyl layer	
Surface mass (g/m <sup>2</sup> )	210
Layer 2: Paper backing	
Surface mass (g/m <sup>2</sup> )	90

Mounting: The product was glued onto a calcium silicate board (12 mm; 870 kg/m<sup>3</sup>) with BK10-PVA adhesive (200 g/m<sup>2</sup>).

## 2. TEST REPORTS AND TEST RESULTS IN SUPPORT OF THIS CLASSIFICATION

### a) Test reports

Name of the laboratory	Name of the sponsor	Test report ref. No.	Test method
WFRGENT nv Ghent, Belgium	Known by the laboratory	12700A, 12700B, 12700C	EN ISO 11925-2 (February 2002)
WFRGENT nv Ghent, Belgium	Known by the laboratory	9634, 12700D, 12700E	EN 13823 (February 2002)
WFRGENT nv Ghent, Belgium	Known by the laboratory	12700G	EXAP according to CEN/TS 15117

b) Test results

Test method	Parameter	Number of tests	Results		Criteria for Class B-s2,d0	
			Continuous parameters Mean	Compliance parameters	Continuous parameters	Compliance parameters
EN ISO 11925-2 (*) (1) 30 s flame application:						
<u>Surface exposure</u> - front side	$F_s \leq 150$ mm Ignition filter paper	6	(-)	Yes	(-)	Yes
<u>Edge exposure</u> - front side	$F_s \leq 150$ mm Ignition filter paper	6	(-)	Yes	(-)	Yes
EN 13823 (2)	FIGRA <sub>0,2 MJ</sub> (W/s) FIGRA <sub>0,4 MJ</sub> (W/s) LFS <sub>&lt;edge</sub> THR <sub>600s</sub> (MJ) SMOGR (m <sup>2</sup> /s <sup>2</sup> ) TSP <sub>600s</sub> (m <sup>2</sup> ) Flaming droplets/particles f < 10 s f > 10 s	3	95 (-) (-) 1,5 18 67 (-) (-)	(-) (-) Yes (-) (-) (-) No No	≤ 120 (-) (-) ≤ 7,5 ≤ 180 ≤ 200 (-) (-)	(-) (-) Yes (-) (-) (-) No No
EN ISO 11925-2 (*) (3) 30 s flame application:						
<u>Surface exposure</u> - front side	$F_s \leq 150$ mm Ignition filter paper	6	(-)	Yes	(-)	Yes
<u>Edge exposure</u> - front side	$F_s \leq 150$ mm Ignition filter paper	6	(-)	Yes	(-)	Yes

(-) Not applicable.

(\*) The material didn't melt nor pull away from the pilot burner.

(1) Based on the results obtained in test report No. 12700A – DESARDI® CLASSIC 290G white, design 2013.

(2) Based on the results obtained in test report No. 9634 – DESARDI® CLASSIC 290G white, design 2013.

(3) Based on the results obtained in test report No. 12700B – DESARDI® CLASSIC 290G black, design 2193.

Test method	Parameter	Number of tests	Results		Criteria for Class B-s2,d0	
			Continuous parameters Mean	Compliance parameters	Continuous parameters	Compliance parameters
EN 13823 (4)	FIGRA <sub>0,2 MJ</sub> (W/s) FIGRA <sub>0,4 MJ</sub> (W/s) LFS <sub>&lt;edge</sub> THR <sub>600s</sub> (MJ) SMOGR (m <sup>2</sup> /s <sup>2</sup> ) TSP <sub>600s</sub> (m <sup>2</sup> ) Flaming droplets/particles f < 10 s f > 10 s	3	18 (-) (-) 1,8 7 55  (-) (-)	(-) (-) Yes (-) (-) (-)  No No	≤ 120 (-) (-) ≤ 7,5 ≤ 180 ≤ 200  (-) (-)	(-) (-) Yes (-) (-) (-)  No No
EN ISO 11925-2 (*) (5) 30 s flame application: <u>Edge exposure</u> - front side	F <sub>s</sub> ≤ 150 mm Ignition filter paper	6	(-) (-)	Yes No	(-) (-)	Yes No
EN 13823 (6)	FIGRA <sub>0,2 MJ</sub> (W/s) FIGRA <sub>0,4 MJ</sub> (W/s) LFS <sub>&lt;edge</sub> THR <sub>600s</sub> (MJ) SMOGR (m <sup>2</sup> /s <sup>2</sup> ) TSP <sub>600s</sub> (m <sup>2</sup> ) Flaming droplets/particles f < 10 s f > 10 s	2	15 (-) (-) 1,7 8 56  (-) (-)	(-) (-) Yes (-) (-) (-)  No No	≤ 120 (-) (-) ≤ 7,5 ≤ 180 ≤ 200  (-) (-)	(-) (-) Yes (-) (-) (-)  No No

(-) Not applicable.

(\*) The material didn't melt nor pull away from the pilot burner.

(4) Based on the results obtained in test report No. 12700D – DESARDI® CLASSIC 290G black, design 2193.

(5) Based on the results obtained in test report No. 12700C – DESARDI® CLASSIC 290G red, design 2423.

(6) Based on the results obtained in test report No. 12700E – DESARDI® CLASSIC 290G red, design 2423.

### 3. CLASSIFICATION AND DIRECT FIELD OF APPLICATION

a) Reference and direct field of application

This classification has been carried out in accordance with EN 13501-1:2007+A1:2009 and prEN 15102:2004.

b) Classification

The product **DESARDI® CLASSIC 290G** in relation to its reaction to fire behavior is classified as:

Fire behavior	Smoke production	Flaming droplets
<b>B</b>	<b>s2</b>	<b>d0</b>

c) Field of application

This classification for the product as described in §1b, is valid for the following end use conditions:

- Substrate: Euroclass A2-s1,d0 or better with a nominal thickness of at least 9 mm and a nominal density of at least 652,5 kg/m<sup>3</sup>
- Without a void
- Fixing: glued with BK10-PVA adhesive (200 g/m<sup>2</sup>)
- With joints

This classification is valid for the following product parameters:

- Nominal surface mass: 300 g/m<sup>2</sup>
- All colours

#### 4. RESTRICTIONS

At the time the standard EN 13501-1:2007+A1:2009 was published, no decision was made concerning the duration of validity of a classification report.

#### 5. WARNING

This classification report does not represent type approval nor certification of the product.

The following statement is included in accordance with Fire Sector Group Recommendation 001:

“The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of a system 3 attestation of conformity and CE marking under the Construction Products Directive.

The manufacturer has made a declaration, which is held on file. This confirms that the product’s design requires no specific processes, procedures or stages (e.g. no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references to the manufacturer’s factory production control that is aimed to be relevant to the samples tested and that will provide for their traceability.”

SIGNED

APPROVED

This document is the original version of this additional classification report and is written in English.  
This report may be used only literally and completely for publications. - For publications of certain texts, in which this report is mentioned, our permission must be obtained in advance.  
The authenticity of the electronic signatures is assured by Belgium Root CA.